


DISCLAIMER: This calculation is based on the best information provided to MaxLite by the client. These findings should be verified by a certified electrical engineer as to their accuracy. Design changes such as wall, ceiling, floor heights and reflectance's of all interior surfaces including partition walls may adversely affect the overall light levels. MaxLite is not responsible as to the veracity of these calculations, and they should only be used as a design reference tool.

Luminaire Location Summary					
LumNo	Label	X	Y	Z	Orient
1	T4-2	145.778	94.703	20	272.22
2	T4-2	218.524	107.748	20	272.22
3	T4-2	316.698	139.367	20	217.085
4	T4-2	360.798	88.38	20	222.47
5	T4-2	86.284	307.16	20	127.946
6	T4-2	48.031	268.023	20	126.026
7	T4-2	290.716	185.576	20	217.085
8	T3	215.744	253.983	20	216.796
9	T3	169.449	313.061	20	216.796

Luminaire Schedule						
Symbol	Qty	Label	Arrangement	Lum. Lumens	LLF	Description
	2	T3	SINGLE	18390	0.900	AR140UT3-40BK
	7	T4-2	2 @ 90 DEGREES	17018	0.900	AR140UT4-40BK

[illegible]

CLIENT:
Date: 4/16/2021
CALC BY: D. Gilmore
THE WORCSHOP PRKNG LOT-A AGI



DISCLAIMER: This calculation is based on the best information provided to MaxLite by the client. These findings should be verified by a certified electrical engineer as to their accuracy. Design changes such as wall, ceiling, floor heights and reflectance's of all interior surfaces including partition walls may adversely affect the overall light levels. MaxLite is not responsible as to the veracity of these calculations, and they should only be used as a design reference tool.